

**TOWNSHIP OF MARLBORO
MONMOUTH COUNTY, NEW JERSEY**

**CONTRACT DOCUMENTS AND SPECIFICATIONS
FOR
H&L SYNTHETIC MULTIPURPOSE FIELD IMPROVEMENTS**

ADDENDUM NO. 1

To all concerned:

The original "Contract Documents and Specifications" for the above project prepared December 2011 are amended as noted herein in this Addendum No. 1.

**CONCERNING THE PLANS, CONTRACT DOCUMENTS AND
SPECIFICATIONS**

1. **On-site soils have not been tested to determine their suitability for re-use onsite. Section 2D of the specifications indicates the requirements for re-use of existing soils and import fill.**
2. **As indicated in the Special Provisions, a Freehold Soil Conservation District Permit is pending for this project. The contractor shall be responsible for obtaining all local (Township) permits necessary for construction as well as required fees in accordance with Township requirements.**
3. **Testing is not required. However, should the contractor deem soil testing is necessary for the removal or disposal of soil, it shall be the contractor's responsibility and will not be paid by the Township.**
4. **Soil borings have not been performed. Initial field investigations indicated that the seasonal high water table was located approximately 55" – 60" below grade.**
5. **If a bidder wishes to substitute a product that is specified in the bid documents, the contractor must include all product data information indicating that the substituted product is an equal to the specified product. Requirements for the synthetic field are included in Section 2I of the specifications.**

End of Addendum No. 1